

Date Prepared 02/2006
Revised 2/24/09 P Watt
Prepared By Patty Watt

BMP Physical Plant #4

TITLE: Underground Tank Inspection

Regulatory Citation:

Applicability:

Tank I.D.	Location
HRC 1 5,000-gallon underground #2 Fuel Oil	To north of HRC
GEN 1 8,000 gallon underground diesel	North side of CoGen

Purpose: Inspection and maintenance of fill port overflow catch basin

Department Responsible: Stationary Engineers

Schedule: Once per week or after rain/snow events.

Procedures: The catch basin of each tank will be inspected and rain/snow melt removed. Remove water by sucking into a container and then emptying this container in to the oil water separator in the Grounds shop.

Do not use the tank drain in the basin to remove water – the sole purpose of this device is to drain fuel spills during delivery back into the tank.

Record Location: N/A

Contact:

Exec Mgr of Physical Plant (629-7427)
Assistant to Exec Mgr 629-7361
Director of Environmental, Health and Safety (629-7163)